



**OUR ENERGY. YOUR POWER.**

**Bredenoord B.V.**

**SOLUTIONS**

Zutphensestraat 319

NL-7325 WT Apeldoorn

PO box 20122

NL-7302 HC Apeldoorn

Phone +31 (0)55 301 85 01

solutions@bredenoord.com

www.bredenoord.com

## **Emission control**

To guarantee the required emission levels from the generator fleet at the upcoming Drilltec project in De Wijk, the set up and operating procedures are as stated below.

### **Emission level**

The required emission level, for NOx is maximum 1.3 gr/kWhr. This is the overall average emission level of De Wijk project and effects, for Bredenoord, the energy production of the Bredenoord generators.

### **Equipment set up**

To achieve this low NOx level, a part of the installed generators is equipped with an exhaust after treatment to reduce the NOx level, the SCR. Four of twelve generators are equipped with a SCR.

### **Effect of SCR**

The effect of the SCR is that it reduces the NOx emission level with 85% to a level of 15% of the starting value

### **Performance of the generator**

All 12 installed 400kVA generators are equipped with Scania DC13-71A engine with emission category Stage 3 or Com3a. The average NOx emission of the whole load range is 4.0 gr/kWhr. The performance of the generator regarding NOx emission is different at various load. As shown below, the best performance regarding NOx is at a load of 75%

<b>Load (%)</b>	<b>NOx (gr/kWhr)</b>
10%	7,9
25%	3,4
50%	3,1
75%	2,8
100%	4,9

A generator load of 75% in combination with a SCR will reduce the NOx level to 0,42 gr/kWhr (15% of 2.8gr/kWhr).

### **Control of percent load**

To achieve the mentioned best performance area of the generator should be loaded to 75% load. The control of the starting and stopping is locked in the engine control system, called Power management. In this system there is a setpoint called " spinning" reserve. The system tries to create an optimum reserve of 25% by starting and stopping generators depending on load demand.



## **De Wijk-Load forecast**

### **Emission level**

The required emission level, for NO<sub>x</sub> is maximum 1.3 gr/kWhr. This is the overall average emission level of De Wijk project and effects, for Bredenoord, the energy production of the Bredenoord generators.

DrillTec provided a load forecast for the planned drill project at De Wijk, customer NAM. Load durations and level can fluctuate, depending on circumstances of ground etc.

Average kW per hour over the project is 645kW, which will be produced by generators equipped with SCR (NO<sub>x</sub> level 0.4 – 0.6 gr/kWhr).

### **Summary**

The average load, 645kW, will be supplied by generators which are equipped with SCR and guarantee a low NO<sub>x</sub> emission level. Only at expected maximum loads the NO<sub>x</sub> level will be slightly higher than the required 1.3 gr/kWhr. The duration of the maximum load is only expected during 13% of the total project time.

Consequently the overall NO<sub>x</sub> emission level will be below the requested 1.3 gr/kWhr.



**G. Elfrink**  
**Operations Manager Solutions**

11 th februar 2020